CERTIFICATE

Issued to: Applicant:

ZHEJIANG MAXGE ELECTRIC TECHNOLOGY CO., LTD.

NO. 299 EAST CHANGHONG ROAD, DEQING ECONOMIC ZONE, WUKANG, DEQING, ZHEJIANG, CHINA P.C: 313200

Manufacturer/Licensee:

ZHEJIANG MAXGE ELECTRIC TECHNOLOGY CO., LTD.

NO. 299 EAST CHANGHONG ROAD, DEQING ECONOMIC ZONE, WUKANG, DEQING, ZHEJIANG, CHINA P.C: 313200

Product(s) : RCCB Trade name(s) : MAXGE

Type(s)/model(s) : SGR, ALR, EPR, EPR-2

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 61008-1:2012 + A1:2014 + A2:2014 + A11:2015,
 EN 61008-2-1:1994 + A11:1998; IEC 61008-1:2010 + A1:2012 + A2:2013; IEC 61008-2-1:1990
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2165673

DEKRA hereby grants the right to use the KEMA-KEUR certification mark,

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 18 August 2016 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 3310153.01

DEKRA Certification B.V.

drs. G.J. Zoetbrood Managing Director F.S. Strikwerda Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE DUTCH ACCREDITATION COUNCIL







ANNEX TO KEMA-KEUR CERTIFICATE 3310153.01

page 1 of 2

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

product : RCCB trade name(s) : MAXGE

type(s) : SGR, ALR, EPR, EPR-2

number of poles : 1P+N, 3P+N

rated current (In) : 16, 20, 25, 32, 40, 50, 63, 80 A

rated residual current (Idn) : 30, 100, 300 mA for 16 A to 80 A, 10mA for 16 A to 25 A

rated voltage (Un) : 240 Vac (1P+N), 415 Vac (3P+N)

behaviour to d.c. components : type A and AC time delay : without time delay

rated conditional short-circuit : 10 kA

current (Inc)

rated conditional residual short- : 10 kA

circuit current (Idc)

rated making and breaking capacity : 500 A or 10 In whichever is greater

(lm)

rated residual making and breaking : 500 A or 10 In whichever is greater

capacity (Idm)

safety distance "a" (grid) : 45 mm

ambient temperature limit : -25 °C ... +40 °C

Additional information

Nomenclature breakdown:

SGR 2 80 30 A a b c d e

a - code denoting the series name: SGR, ALR, EPR or EPR-2

b - code denoting the number of pole: 2= 1P+N, 4= 3P+N

c - code denoting the current rating: 16, 20, 25, 32, 40, 50, 63, 80 A d - code denoting the residual current rating: 10, 30, 100, 300 mA

e - code denoting the type of RCCB: A= type A, AC= type AC

TESTS

Test requirements

EN 61008-1:2012 + A1:2014 + A2:2014 + A11:2015

EN 61008-2-1:1994 + A11:1998

IEC 61008-1:2010 + A1:2012 + A2:2013

IEC 61008-2-1:1990

Test result

The test results are laid down in DEKRA test file 3310153.01 and test report 3310153.50 and also based on LCIE CB certificate no. FR 685060 issued on 2016-04-07 with test reports no. B180008-01 to 08 issued on 2016-03-22, test reports no. B120048-00 Amendment No.1:2016-01-07, B120048 -19 and 20 issued on 2016-01-07 and test reports no. B120048-00 to 18 issued on 2013-05-28.



ANNEX TO KEMA-KEUR CERTIFICATE 3310153.01

page 2 of 2

Conclusion

The examination proved that all test requirements were met.

Tested by : LCIE and Lester Wang

Checked by : Eric Wang

Factory locations

ZHEJIANG MAXGE ELECTRIC TECHNOLOGY CO., LTD. NO. 299 EAST CHANGHONG ROAD, DEQING ECONOMIC ZONE, WUKANG, DEQING, ZHEJIANG,

CHINA P.C: 313200